ООО Закупром Тепло А.Н. ува ов

Температурный график работы котельных ООО «Джи-пром Тепром Тепро

Температура наружного воздуха	Температура в подающей линии	Температура в ображительной
-35	85,0	66,0
-34	84,0	66,0
-33	83,0	66,0
-32	82,0	66,0
-31	80,0	65,0
-30	78,0	63,0
-29	77,0	62,0
-28	75,0	60,0
-27	73,0	58,0
-26	72,0	57,0
-25	70,0	55,0
-24	68,0	53,0
-23	66,0	51,0
-22	64,0	49,0
-21	62,0	46,0
-20	60,0	45,0
-19	58,0	43,0
-18	56,0	41,0
-17	55,0	40,0
-16	54,0	39,0
-15	53,0	38,0
-14	52,0	37,0
-13	51,0	36,0
-12	50,0	35,0
-11	49,0	34,0
-10	48,0	34,0
-9	47,0	34,0
-8	46,0	33,0
-7	45,0	33,0
-6	44,0	33,0
-5	43,0	32,0
-4	43,0	32,0
-3	43,0	31,0
-2	42,0	31,0
-1	42,0	30,0
0	41,0	30,0
1	41,0	29,0
2	41,0	29,0
3	40,0	29,0
4	40,0	28,0
5	40,0	28,0
6	39,0	27,0
7	39,0	27,0
8	38,0	26,0

Примечание: Допускается отклонение температуры согласно графика + - 2,0 град.

Согласовано:

Технический директор

Д.С. Митрошин